

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**

**ESTE INFORME CONTIENE INFORMACION MUY IMPORTANTE SOBRE SU AGUA DE BEBER. TRADUZCALO O HABLE CON ALGUIEN QUE LO ENTIENDA BIEN.**

**Monitoring Requirements Not Met for Topton Borough Water**

Our water system violated drinking water standards over the past year. Even though this was not an emergency, as our customers, you have a right to know what happened and what we did to correct this situation.

*We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 2017 we did not complete all monitoring or testing for all contaminants and therefore cannot be sure of the quality of our drinking water during that time.*

**What should I do?**

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the year, how often we are supposed to sample for these contaminants and how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were or will be taken
Turbidity	Continuously	0	December 8, 9 and 10, 2017	December 11, 2017
TTHM	Triennially	0	April 5 – 11, 2017	April 12, 2017

**What happened? What was done?**

We have continuous turbidity monitoring and recording equipment. On December 8, 2017 the recording equipment malfunctioned and we did not detect the problem until December 11, 2017. During this period, our monitoring equipment was functional and do not believe there were any problems, but we failed to record the data.

The TTHM sample was collected on time but was not properly preserved and had to be collected again.

For more information, please contact Borough of Topton at 610-682-2541.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

This notice is being sent to you by Topton Borough Water

PWS ID#: 3060072

Date distributed: 4/20/2018